

20190508 Public comment on DR AS/CA S009:2019 from BICSI South Pacific

Submitted via the "Submit Comments" webpage:

Comment is on: DR S009:2019

Name: Wayne Valent

Organisation / Affiliation: BICSI South Pacific

Your Comments: Section 16.1 Cable Flammability - this section requires a clearer statement regarding the application of the Building Code and approval of the installation method and products used by an accredited building certifier. It is unrealistic to expect that an Open Registered Cabler would understand how to apply the NCC or BCA in direct relation to the installation of highly flammable outdoor construction cable within the confines of a building. Note 1 continues to be confusing in stating that it is not a requirement to change cable construction should a cable be exiting the building at another location. It would serve the industry better to have a clear direct statement that all cabling installed indoors shall be compliant indoor cabling or the installation shall be compliant to the requirements of the BCA/NCC. The note should give better guidance on how to comply to the BCA/NCC. Note 2 is irrelevant to a cabler who does not understand the BCA/NCC.

Attach a file?: No file uploaded