

20190522 Public comment on DR AS/CA S009:2019 from Telstra 1

Submitted via the "Submit Comments" webpage:

Comment is on: DR S009:2019

Name: Bruce Dewar

Organisation / Affiliation: Telstra

Your Comments: Suggested changes to Section 16.2 Fire stopping Any opening where customer cabling runs in or through a fire isolating element such as a wall, floor or riser shaft, shall— (a) be suitably fire stopped to maintain the original fire rating performance; and (b) comply with the Building Code. Note 1. The penetrating cable's sheath must be a fire resistant or retardant rated cable sheath, to maintain the original fire rating performance of the fire isolating element.

Attach a file?: No file uploaded